

# Inventory Summary

PWS Name: Senna Hills Municipal Utility District  
 PWSID: TX2270316

**Purpose of this worksheet:** For water systems to provide a summary of the service line inventory, including information on ownership, inventory format, and the number of service lines for each of the four required materials classifications.

**Note:** Cells that have a superscript<sup>x</sup> are required fields.

Part 1. General Information	
1. Is this the <b>Initial Inventory</b> or an <b>Inventory Update</b> ? <sup>x</sup>	Initial Inventory
2a. Who <b>owns the service lines</b> in your system? <i>If other, please explain below</i> <sup>x</sup>	Ownership is split
2b. Is there documentation that defines service line ownership in your system, such as a local ordinance? <i>If yes, please describe below and explain where ownership is split (e.g., property line, curb stop).</i>	Yes
3a. Describe when lead service lines were generally installed in your system below.  <b>No lead pipes were installed in this system.</b>	
3b. When were lead service lines banned for the system? Reference the state or local ordinance that banned the use of lead in your system. <b>1967 CoA bans lead piping in plumbing.      1988 state wide adoption of EPA lead waterline ban.</b>	
4. Are there lead goosenecks, pigtails or connectors in the system?	No

## Part 2. Inventory Summary Table<sup>1</sup>

When using the **Detailed Inventory** worksheet, the classifications in the Column "Entire Service Line Material Classification" (Column Q) will be used to calculate the total number of service lines for each of the four material classifications below. **Remember this is the classification for the entire service line.**

Service Line Material Classification	Definition	Total Number of Service Lines (REQUIRED to be reported under the LCRR) <sup>x</sup>
<b>Lead</b>	Any portion of the service line is known to be made of lead. <sup>2</sup>	0
<b>Galvanized Requiring Replacement (GRR)</b>	The service line is not made of lead, but a portion is galvanized and the system is unable to demonstrate that the galvanized line was never downstream of a lead service line.	0
<b>Non-Lead</b>	All portions of the service line are known NOT to be lead or GRR through an evidence-based record, method, or technique.	407
<b>Lead Status Unknown</b>	The service line material is not known to be lead or GRR. For the entire service line or a portion of it (in cases of split ownership), there is not enough evidence to support material classification.	0
<b>TOTAL</b>		407

**Notes**

<sup>1</sup>This summary table is for reporting material for the entire service line connecting the water main to the customer's plumbing. See the **Classifying SLs** worksheet for additional guidance on assigning a materials classification to the entire service line when ownership is split. Remember that systems must track the system-owned and customer-owned portions separately in their inventory.

<sup>2</sup>A lead-lined galvanized service line is consistent with the definition of an LSL under the LCRR ("a portion of pipe that is made of lead, which connects the water main to the building inlet") (40 CFR §141.2) and must therefore be classified in the inventory as an LSL. Do not, however, count non-lead service lines with a lead gooseneck or pigtail as lead service lines.

## Detailed Inventory

PWS Name: Senna Hills Municipal Utility District  
 PWSID: TX2270316

**Purpose of this worksheet:** To provide a format water systems can use to track materials for each service line in the distribution system.

**General Instructions:** Each row in this worksheet represents one service line connecting the water main to the customer's plumbing. The worksheet includes required and recommended elements; the columns with the aqua shading are required by the LCR. The worksheet includes examples in rows 12 - 20 and is formatted for approximately 10,000 entries.

**Note:** Cells that have a superscript <sup>1</sup> are required fields; cells that have a superscript <sup>2</sup> are conditionally required fields and can impact formulas throughout document.

TCEQ-20943 (Rev. 1/25/2023)

Unique Service Line ID	Location Information						System-Owned Portion			Customer-Owned Portion			Entire Service Line Material Classification <sup>1</sup>	Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line Replacement				
	Street Name <sup>1</sup>	City <sup>1</sup>	Zip Code <sup>1</sup>	Other Location Identifier <sup>1</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>1</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>1</sup>	Service Line Installation Date <sup>2</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>1</sup>	Service Line Installation Date <sup>2</sup>		Notes	Is there a Lead Connector? <sup>1</sup>	Is there Lead Solder in the Service Line? <sup>1</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR		
A Unique ID is recommended for each service line.	Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include a landmark, intersection, block, or other details to specify service line locations. If using GPS coordinates, utilize the GPS coordinate - Latitude/Longitude fields and include 5 decimal places.						Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field			Select Yes, No, or Don't know. Important for determining if downstream customer-owned galvanized service line requires replacement	Dropdown list when the service line was installed or replaced	Use this field for documenting additional relevant information, including when classification changes.	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Date, year, or estimated date range when the service line was installed or replaced	Can use this field for documenting additional relevant information, including when classification changes.	Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown	For example, lead gooseneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't know	For example, backflow preventer or meter containing lead	Note: This information may be helpful for identifying lead tap monitoring locations.						
1	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
2	BIDENS PLACE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
3	BIDENS PLACE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
4	RIVINA DRIVE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
5	BIDENS PLACE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
6	RIVINA DRIVE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
7	RIVINA DRIVE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
8	BIDENS PLACE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
9	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
10	RIVINA DRIVE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
11	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
12	BIDENS PLACE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
13	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
14	BIDENS PLACE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
15	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
16	BIDENS PLACE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
17	RIVINA DRIVE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
18	BIDENS PLACE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
19	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
20	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
21	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
22	RIVINA DRIVE	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
23	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
24	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
25	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
26	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
27	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			
28	RIVINA DR	Austin	78733	Sec 10			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead										Tier 5			



CEQ-20943 (Rev. 1/25/2023)																										
Unique Service Line ID	Location Information						System-Owned Portion				Customer-Owned Portion			Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering						Lead Service Line Replacement			
	Street Name*	City*	Zip Code*	Other Location Identifier*	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification*	If Non-Lead in Column J, Was Material Ever Previously Lead?†	Service Line Installation Date†	Notes	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date†	Notes	Entire Service Line Material Classification*	Is there a Lead Connector?‡	Is there Lead Solder in the Service Line?‡	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR		
56	GILIA DRIVE	Austin	78733	Sec 11			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
57	GILIA DR	Austin	78733	Sec 11			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
58	DATURA COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
59	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
60	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
61	TRILLIUM COVE	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
62	DATURA COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
63	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
64	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
65	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
66	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
67	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
68	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
69	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
70	TRILLIUM COVE	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
71	TRILLIUM COVE	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
72	TRILLIUM COVE	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
73	TRILLIUM COVE	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
74	TRILLIUM COVE	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
75	INDIGO BROOM LOOP	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
76	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
77	YARROW COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
78	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
79	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
80	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
81	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		
82	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5		

CEQ-20943 (Rev. 1/25/2023)																											
Unique Service Line ID	Location Information						System-Owned Portion				Customer-Owned Portion			Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering						Lead Service Line Replacement				
	Street Name*	City*	Zip Code*	Other Location Identifier*	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification*	If Non-Lead in Column J, Was Material Ever Previously Lead?†	Service Line Installation Date†	Notes	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date†	Notes	Entire Service Line Material Classification*	Is there a Lead Connector?‡	Is there Lead Solder in the Service Line?‡	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site?	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR			
83	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5			
84	DATURA COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
85	INDIGO BROOM LOOP	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
86	INDIGO BROOM LOOP	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
87	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
88	INDIGO BROOM LOOP	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
89	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
90	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
91	PEONIA CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
92	TRILLIUM COVE	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
93	TRILLIUM COVE	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
94	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
95	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
96	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
97	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
98	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
99	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
100	DATURA COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
101	DATURA COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
102	INDIGO BROOM LOOP	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
103	INDIGO BROOM LOOP	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
104	INDIGO BROOM LOOP	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
105	INDIGO BROOM LOOP	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
106	DATURA COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
107	YARROW COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
108	YARROW COURT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
109	LEMON MINT CT	Austin	78733	Sec 1-A			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		









CEQ-20943 (Rev. 1/25/2023)																											
Unique Service Line ID	Location Information						System-Owned Portion				Customer-Owned Portion			Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line Replacement					
	Street Name*	City*	Zip Code*	Other Location Identifier*	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification*	If Non-Lead in Column J, Was Material Ever Previously Lead?†	Service Line Installation Date*	Notes	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date*	Notes	Entire Service Line Material Classification*	Is there a Lead Connector?‡	Is there Lead Solder in the Service Line?‡	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?‡	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?‡	Current LCR Sampling Site?‡	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR			
192	INDIGO BROOM LOOP	Austin	78733	Sec 2			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead										Tier 5			
193	INDIGO BROOM LOOP	Austin	78733	Sec 2			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
194	INDIGO BROOM LOOP	Austin	78733	Sec 2			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
195	INDIGO BROOM LOOP	Austin	78733	Sec 2			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
196	COREOPSIS DR	Austin	78733	Sec 2			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
197	PLUCHEA CV	Austin	78733	Sec 2			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
198	PLUCHEA CV	Austin	78733	Sec 2			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
199	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
200	INDIGO BROOM LOOP	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
201	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
202	INDIGO BROOM LOOP	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
203	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
204	RIVINA DR	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
205	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
206	INDIGO BROOM LOOP	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
207	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
208	RIVINA DR	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
209	SENNA HILLS DR	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
210	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
211	RIVINA DR	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
212	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
213	RIVINA DR	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
214	RIVINA DR	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
215	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
216	SENNA HILLS DR	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
217	RIVINA DR	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		
218	VERVAIN COURT	Austin	78733	Sec 4			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead											Tier 5		





CEQ-20943 (Rev. 1/25/2023)																								
Unique Service Line ID	Location Information						System-Owned Portion			Customer-Owned Portion			Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering						Lead Service Line Replacement		
	Street Name*	City*	Zip Code*	Other Location Identifier*	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification*	If Non-Lead in Column J, Was Material Ever Previously Lead?†	Service Line Installation Date†	Notes	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date†	Notes	Entire Service Line Material Classification*	Is there a Lead Connector?‡	Is there Lead Solder in the Service Line?‡	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?‡	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?‡	Current LCR Sampling Site?‡	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
273	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
274	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
275	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
276	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
277	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
278	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
279	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
280	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
281	ACACIA BUD DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
282	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
283	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
284	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
285	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
286	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
287	ACACIA BUD DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
288	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
289	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
290	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
291	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
292	PREZIA DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
293	STRAWFLOWER DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
294	STRAWFLOWER DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
295	STRAWFLOWER DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
296	ACACIA BUD DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
297	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
298	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
299	STRAWFLOWER DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		

CEQ-20943 (Rev. 1/25/2023)																								
Unique Service Line ID	Location Information						System-Owned Portion				Customer-Owned Portion			Entire Service Line Material Classification <sup>6</sup>	Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line Replacement	
	Street Name <sup>1</sup>	City <sup>2</sup>	Zip Code <sup>3</sup>	Other Location Identifier <sup>4</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>5</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>7</sup>	Service Line Installation Date <sup>8</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>9</sup>	Service Line Installation Date <sup>10</sup>	Notes		Is there a Lead Connector? <sup>11</sup>	Is there Lead Solder in the Service Line? <sup>12</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present? <sup>13</sup>	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site? <sup>14</sup>	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
300	ACACIA BUD DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
301	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
302	STRAWFLOWER DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
303	STRAWFLOWER DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
304	ACACIA BUD DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
305	ACACIA BUD DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
306	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
307	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
308	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
309	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
310	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
311	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
312	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
313	STRAWFLOWER DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
314	ACACIA BUD DR	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
315	STRAWFLOWER DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
316	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
317	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
318	STRAWFLOWER DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
319	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
320	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
321	PREZIA DRIVE	Austin	78733	Sec 6			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
322	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
323	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
324	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
325	STRAWFLOWER DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
326	MILAGRO	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			

CEQ-20943 (Rev. 1/25/2023)																								
Unique Service Line ID	Location Information						System-Owned Portion			Customer-Owned Portion			Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering						Lead Service Line Replacement		
	Street Name*	City*	Zip Code*	Other Location Identifier*	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification*	If Non-Lead In Column J, Was Material Ever Previously Lead?†	Service Line Installation Date†	Notes	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date†	Notes	Entire Service Line Material Classification*	Is there a Lead Connector?‡	Is there Lead Solder in the Service Line?‡	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?‡	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?‡	Current LCR Sampling Site?‡	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
327	MILAGRO	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
328	SPIDERLING CT	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
329	STRAWFLOWER DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
330	STRAWFLOWER DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
331	PURSLANE COVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
332	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
333	STRAWFLOWER DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
334	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
335	PURSLANE COVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
336	SPIDERLING CT	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
337	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
338	STRAWFLOWER DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
339	SPIDERLING CT	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
340	SENNA HILLS DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
341	STRAWFLOWER DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
342	STRAWFLOWER DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
343	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
344	SPIDERLING CT	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
345	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
346	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
347	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
348	GALLARDIA DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
349	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
350	MILAGRO DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
351	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
352	SENNA HILLS DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		
353	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead								Tier 5		

CEQ-20943 (Rev. 1/25/2023)																								
Unique Service Line ID	Location Information						System-Owned Portion				Customer-Owned Portion			Entire Service Line Material Classification <sup>6</sup>	Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering					Lead Service Line Replacement	
	Street Name <sup>1</sup>	City <sup>2</sup>	Zip Code <sup>3</sup>	Other Location Identifier <sup>4</sup>	GPS Coordinate - Latitude (decimal degrees)	GPS Coordinate - Longitude (decimal degrees)	System-Owned Portion Service Line Material Classification <sup>5</sup>	If Non-Lead in Column J, Was Material Ever Previously Lead? <sup>7</sup>	Service Line Installation Date <sup>8</sup>	Notes	Customer-Owned Portion Service Line Material Classification <sup>9</sup>	Service Line Installation Date <sup>10</sup>	Notes		Is there a Lead Connector? <sup>11</sup>	Is there Lead Solder in the Service Line? <sup>12</sup>	Describe Other Fittings and Equipment Connected to the Service Line that Contain Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present? <sup>13</sup>	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before July 1, 1988?	Current LCR Sampling Site? <sup>14</sup>	Sample Site Selection Criteria (Site Tier)	Date of System-owned LSLR	Date of Customer-owned LSLR
354	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
355	MILAGRO DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
356	STRAWFLOWER DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
357	MILAGRO DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
358	MILAGRO	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
359	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
360	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
361	PURSLANE COVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
362	PURSLANE COVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
363	MILAGRO DRIVE	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
364	STRAWFLOWER DR	Austin	78733	Sec 7			Non-Lead - Copper	No	Between 1989 and 2014	Service line specified as type "K" copper tubing.	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
365	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
366	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
367	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
368	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
369	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
370	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
371	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
372	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
373	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
374	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
375	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
376	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
377	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
378	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
379	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			
380	GALLARDIA DRIVE	Austin	78733	Sec 8			Non-Lead	No	Between 1989 and 2014	Service Line specified as either copper tubing or black polyethylene	Non-Lead	Between 1989 and 2014	Specified as meeting the Austin Plumbing Code Requirements, which as of 1986 does not allow lead	Non-Lead							Tier 5			

